

Appendix B

NO.	LIFT STATION	ADDRESS	*100 AMP 3 PHASE OUTLET	**TRANSFER SWITCH	***RACK ASSEMBLY	****REWIRE PHASING
1	Footlocker	3302 S. US Highway 77	XX	XX	XX	XX
2	Highland Drive	1507 Highland Drive	XX	XX	XX	XX
3	Candlelight Drive	1456 Candlelight Lane	XX	XX	XX	XX
4	Elmdale (Northwind)	1935 Northwind Drive	XX	XX		XX
5	Hoover Road	100 Hoover Road	XX	XX		XX
6	Mobile Traveler	2317 N. Jackson St.	XX	XX	XX	XX
7	40 US 77	Gateway Court	XX	XX		XX
8	Goldenbelt Blvd.	1001 Goldenbelt Blvd.	XX			XX
9	East Street	630 East Street	XX	XX	XX	XX
10	East Chestnut St.	400 East Chestnut St.	XX	XX	XX	XX
11	Grant Ave (Regency)	948 Grant Ave.	XX	XX	XX	XX
12	East Ash	100 blk E. Ash	XX	XX		XX
13	Faith Tabernacle	Rucker Rd	XX			XX
14	Doc Hargraves #2	Brooke Bend	XX			XX
15	Doc Hargraves #5	Nicole	XX			XX
16	Olivia Farms	2700 Fort Ave.	XX			XX
17	Olivia Farms	2500 Wilma Way	XX			XX
18	Village at Freedom Place	Fuller Circle	XX	XX		XX
19	Osprey Ct.	2330 Osprey Ct.	XX	XX		XX
20	Jaeger Dr.	2550 Jaeger Drive	XX	XX		XX
21	Michael's Run	Caroline Ct.	XX			XX

* 100 AMP - Furnish and install a 100 amp 3 phase pin and sleeve outlet for connection to the generator

** Furnish and install a 100 AMP 3 phase nema 3r non fused manual trasfer switch

*** Furnish and install a new rack assembly for installation of the new equipment.

**** Check and rewire the lift station phasing to match the portable generator hookup